

**TEST REPORT FOR COMPLIANCE WITH EN 60204-1: 1997**  
*Safety of machinery- Electrical equipment of machines, part 1: General requirement*

<b>Report No.</b>	EZ/2007/80024	
<b>Applicant</b>		
<b>Name</b>	Ya De Li Technology Co., Ltd.	
<b>Address</b>	1F, No. 5, Alley 39, Lane 64, Sec. 1, Beisin Road, Sindian City, Taipei County 231, Taiwan (R.O.C.)	
<b>Machinery</b>		
<b>Name</b>	Frequency Conversion Saving System of Compressor in the outside type	
<b>Model</b>	VR2220A、VR2220、VR3820A、VR3820、VR4420A、VR4420、VR2215A、VR2215、VR3815A、VR3815、VR4415A、VR4415、VR2210A、VR2210、VR3810A、VR3810、VR4410A、VR4410、VR2275A、VR2275、VR3875A、VR3875、VR4475A、VR4475、OP2220、OP3820、OP4420、OP2215、OP3815、OP4415、OP2210、OP3810、OP4410、OP2275、OP3875、OP4475	
未經亞得力科技股份有限公司同意，嚴禁下載使用。		
<b>Date of Test</b>	Sep. 05, 2007	
<b>Test Site</b>	134, Wu Kung Road WuKu Industrial Zone, Taipei County, Taiwan 24803	
<b>Tested by</b>	Gary Huang	<i>Gary Huang</i>
<b>Approved by</b>	Jason Lin	

**Note:**

1. The test results only responds to the tested sample, and is invalid as separately used.
2. Reproduction of this report without a written approval is strictly prohibited.

**1-1 Machine under test**

- Name : Frequency Conversion Saving System of Compressor in the outside type
- MODEL : VR2220
- SUPPLY : AC 3 $\phi$  , 220V, 50/60Hz



Front view of machine



Side view of machine



Back view of machine



Control panel of machine

未經亞得力士科技股份有限公司同意，嚴禁下載使用。

**2-1 Earth continuity test****Criteria:**

Inject a current of at least 10A at 50Hz or 60Hz derived from a PELV source between the PE terminal and relevant points that are of the protective bonding circuit. The measured voltage between the PE terminal and the points of test shall not exceed the values in the table shown below.

<i>Minimum effective protective conductor cross-sectional area of the branch under test</i> <i>mm<sup>2</sup></i>	<i>Maximum measured voltage drop (values are given for a test current of 10A)</i> <i>V</i>
1.0	3.3
1.5	2.6
2.5	1.9
4.0	1.4
>6.0	1.0

**Test instruments**


Item	Brand	Model/SER. No.	Calibration Due
Earth continuity tester	CHYNG HONG	CG-503	Aug 6,2008

**Description of the test:**

- a. Inject a current 10A at 50/60Hz derived from the earth continuity tester between the PE terminal and test points, then read the voltage drops of them.
- b. The relevant point is considered to have passed the test, when its voltage drop is below the value shown in the above table.

Test results

Test points	Cross-sectional Area of the branch under test (mm <sup>2</sup> )	Voltage drop	Result
1 PE to Enclosure	--	--	Pass



Earth continuity test

未經亞得力科技股份有限公司同意，嚴禁下載使用。

## 2.2 Insulation resistance tests

Criteria: *The insulation resistance measured at 500 V d.c. between the power circuit conductors and the protective bonding circuit shall not less than 1 M $\Omega$*

### Test instruments

Item	Brand	Model/SER. No.	Calibration Due
Insulation tester	EXTECH	7120	Jul. 10, 2008

### Test results

	Test points	Insulation resistance (M $\Omega$ )	Result
1	Enclosure to mains supply wiring L1 (3 $\phi$ , 220V)	1.29 M $\Omega$	Pass
2	Enclosure to mains supply wiring L2 (3 $\phi$ , 220V)	1.19 M $\Omega$	Pass
3	Enclosure to mains supply wiring L3 (3 $\phi$ , 220V)	1.11 M $\Omega$	Pass



Insulation resistance test

未經亞得力科技股份有限公司同意，嚴禁下載使用。

### 2.3. High voltage tests

Criteria:

The electrical equipment shall withstand a test voltage applied for a period of at least one second between the conductors of all circuits and protective bonding circuit, except for those circuits intended to operate at or below PELV voltages. The test voltage shall:

have a value of twice the rated supply voltage of the equipment or 1000V, whichever is the greater;

- be at a frequency of 50/60 Hz;

- be supplied from a transformer with a minimum rating of 500 VA.

Test instruments

Item	Brand	Model/SER. No.	Calibration Due
Insulation tester	EXTECH	7120	Jul. 10, 2008

Description of the test:

- a. Inject a voltage of 1000V at 50/60Hz derived from the voltage tester for 10s between the PE terminal and test points
- b. The relevant point is considered to have passed the test, when there is no flash over or breakdown occurred during the tests.

Test results

	Test points	Applied Voltage	Result
1	Enclosure to mains supply wiring L1 (3 $\phi$ , 220V)	2000V	Pass
2	Enclosure to mains supply wiring L2 (3 $\phi$ , 220V)	2000V	Pass
3	Enclosure to mains supply wiring L3 (3 $\phi$ , 220V)	2000V	Pass



未經亞得力科技股份有限公司同意，嚴禁下載使用。

High voltage test

**2.4. Residual voltage tests**

**Criteria:**

Live parts having a residual voltage greater than 60V after the supply has been disconnected shall be discharged to 60V or less within a time period of 5s after disconnection of the supply voltage.

Test instruments

Item	Brand	Model/SER. No.	Calibration Due
--	--	--	--

Description of the test:

The residual voltage between each phase of the supply conductors was measured after supply voltage was switched off.

Test results

Measured points	Residual Voltage	Discharge time(second)	Result
--	--	--	--

Note : EUT is a fixed equipment, no residual voltage tests needed.